

Attention: T288888 / CRAIG MERKORD / DAYVILLE SCHOOL DISTRICT 16J

Kit #: 7158863 Result: 0.9 ± 0.3 pCi/l
Location: 1st Floor Gym

Analysis Note :
Analyzed : 2017-04-03 at 4:00 pm
Started : 2017-03-27 at 7:00 am
Ended : 2017-03-29 at 3:00 pm
Hours/MST% : 56 hours 6.6% 60°F

Kit #: 7158864 Result: 1.3 ± 0.4 pCi/l
Location: 1st Floor K-2

Analysis Note :
Analyzed : 2017-04-03 at 4:00 pm
Started : 2017-03-27 at 7:00 am
Ended : 2017-03-29 at 3:00 pm
Hours/MST% : 56 hours 4.4% 70°F

Kit #: 7158865 Result: 0.6 ± 0.4 pCi/l
Location: 1st Floor Ms

Analysis Note :
Analyzed : 2017-04-03 at 5:00 pm
Started : 2017-03-27 at 7:00 am
Ended : 2017-03-29 at 4:00 pm
Hours/MST% : 57 hours 5.1% 70°F

Kit #: 7158866 Result: ????
Location: 1st Floor Pb

Analysis Note : NI
Analyzed : 2017-04-03 at 4:00 pm
Started : 2017-03-27 at 4:00 pm
Ended : 2017-03-29 at 7:00 am
Hours/MST% : 39 hours 5.9% 70°F

Kit #: 7158867 Result: 1.1 ± 0.4 pCi/l
Location: Basement Hall

Analysis Note :
Analyzed : 2017-04-03 at 4:00 pm
Started : 2017-03-27 at 7:00 am
Ended : 2017-03-29 at 4:00 pm
Hours/MST% : 57 hours 5.8% 70°F

Kit #: 7158868 Result: 1.3 ± 0.4 pCi/l
Location: 1st Floor ~~PB~~ ~~SL~~

Analysis Note :
Analyzed : 2017-04-03 at 4:00 pm
Started : 2017-03-27 at 7:00 am
Ended : 2017-03-29 at 4:00 pm
Hours/MST% : 57 hours 5.2% 70°F

Attention: T288888 / CRAIG MERKORD / DAYVILLE SCHOOL DISTRICT 16J

Kit #: 7158869 Result: ????

Location: 1st Floor Caf

Analysis Note : MI

Analyzed : 2017-04-03 at 4:00 pm

Started : 2017-03-27 at 7:00 am

Ended : 2017-03-29 at

Hours/MST% : 0 hours 6.6% 70°F

Kit #: 7158870 Result: 1.1 ± 0.3 pCi/l

Location: 1st Floor Gym *stage*

Analysis Note :

Analyzed : 2017-04-03 at 4:00 pm

Started : 2017-03-27 at 8:00 am

Ended : 2017-03-29 at 3:00 pm

Hours/MST% : 55 hours 5.8% 60°F

Kit #: 7158871 Result: 0.7 ± 0.4 pCi/l

Location: 1st Floor Shop

Analysis Note :

Analyzed : 2017-04-03 at 4:00 pm

Started : 2017-03-27 at 7:00 am

Ended : 2017-03-29 at 3:00 pm

Hours/MST% : 56 hours 5.2% 70°F

Kit #: 7158872 Result: 0.5 ± 0.4 pCi/l

Location: 1st Floor Lib

Analysis Note :

Analyzed : 2017-04-03 at 4:00 pm

Started : 2017-03-27 at 7:00 am

Ended : 2017-03-29 at 4:00 pm

Hours/MST% : 57 hours 5.2% 70°F

Kit #: 7158875 Result: < 0.3 pCi/l

Location: 1st Floor 3-5

Analysis Note :

Analyzed : 2017-04-03 at 4:00 pm

Started : 2017-03-27 at 7:00 am

Ended : 2017-03-29 at 3:00 pm

Hours/MST% : 56 hours 5.8% 70°F

Kit #: 7158876 Result: 1.0 ± 0.4 pCi/l

Location: 1st Floor *Rec Rm*

Analysis Note :

Analyzed : 2017-04-03 at 5:00 pm

Started : 2017-03-27 at 7:00 am

Ended : 2017-03-29 at 3:00 pm

Hours/MST% : 56 hours 5.2% 70°F

April 5, 2017

**** LABORATORY ANALYSIS REPORT ****

Pg 3 of 3

Attention: T28888 / CRAIG MERKORD / DAYVILLE SCHOOL DISTRICT 16J

Kit #: 7158877 Result: 1.1 ± 0.4 pCi/l

Location: 1st Floor Mp

Analysis Note :

Analyzed : 2017-04-03 at 4:00 pm

Started : 2017-03-27 at 7:00 am

Ended : 2017-03-29 at 4:00 pm

Hours/MST% : 57 hours 5.9% 70°F

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498