

Lead in Water Test Results Summary: Dayville School District All Buildings

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **equal to or greater than the Action Level** of 15 ppb are **highlighted in red and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **near the Action Level** of 15 ppb (11.99 to 14.99 ppb) are **highlighted in yellow and precede a "Med" (Medium) value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Science Room Sink #1	22091363-01	9/30/2022	ND	Low			
Science Room Sink #2	22091363-02	9/30/2022	ND	Low			
Science Room Sink #3	22091363-03	9/30/2022	ND	Low			
Staff RR Sink Faucet	22091363-06	9/30/2022	ND	Low			
Staff Lounge Faucet	22091363-05	9/30/2022	ND	Low			
Boys RR Sink Faucet	22091363-04	9/30/2022	ND	Low			
High School Hall Fountain	22091363-07	9/30/2022	ND	Low			
Girls RR Sink Faucet	22091363-08	9/30/2022	ND	Low			
Cafeteria Large Sink	22091363-09	9/30/2022	ND	Low			
Cafeteria Small Sink	22091363-10	9/30/2022	ND	Low			
Gym Fountain	22091363-11	9/30/2022	ND	Low			
Girls Gym RR Sink	22091363-12	9/30/2022	ND	Low			
Boys Gym RR Sink	22091363-13	9/30/2022	ND	Low			
Gym Foyer Closed Sink	22091363-14	9/30/2022	ND	Low			
Gym Front Hose	22091363-15	9/30/2022	ND	Low			
Gym Concession Stand Sink	22091363-16	9/30/2022	ND	Low			
Gym Referee Room	22091363-17	9/30/2022	ND	Low			
Gym Girls Locker Room Sink	22091363-18	9/30/2022	ND	Low			
Gym Girls Locker Room Fountain	22091363-19	9/30/2022	ND	Low			
Gym Boys Locker Room Sink	22091363-20	9/30/2022	ND	Low			
Gym Boys Locker Room Fountain	22091363-21	9/30/2022	ND	Low			
Gym Laundry Room	22091363-39	9/30/2022	ND	Low			
Elementary Girls RR Sink	22091363-22	9/30/2022	ND	Low			
Elementary Boys RR Sink	22091363-23	9/30/2022	ND	Low			
Elementary Hall Fountain	22091363-24	9/30/2022	ND	Low			
Elementary Outside Faucet	22091363-25	9/30/2022	ND	Low			
Elementary Teacher's Lounge Sink	22091363-26	9/30/2022	ND	Low			
ELC Main Sink	22091363-27	9/30/2022	ND	Low			
ELC RR Sink	22091363-28	10/1/2022	ND	Low			
CTE Shop Outside Faucet	22091363-29	10/1/2022	ND	Low			
CTE Shop Main Faucet	22091363-30	10/1/2022	ND	Low			
CTE Shop RR Sink	22091363-31	10/1/2022	ND	Low			
District House Outside Faucet	22091363-32	10/1/2022	ND	Low			
District House Guest BR Sink	22091363-33	10/1/2022	ND	Low			
District House Kitchen Sink	22091363-34	10/1/2022	ND	Low			
District House Master BR Sink	22091363-35	10/1/2022	ND	Low			
Football Field Outside Faucet	22091363-36	10/1/2022	ND	Low			
Football Field Girls RR Sink	22091363-37	10/1/2022	ND	Low			
Football Field Boys RR Sink	2209-1363-38	10/1/2022	ND	Low			